

- CODE OF ORDINANCES
Chapter 14 - WATER AND SEWERS
ARTICLE III. - SEWERS

DIVISION 5. PRETREATMENT

DIVISION 5. PRETREATMENT

[Subdivision I. - General Provisions](#)

[Subdivision II. - General Sewer Use Requirements](#)

[Subdivision III. - Pretreatment of Wastewater](#)

[Subdivision IV. - Individual Wastewater Discharge Permits](#)

[Subdivision V. - Individual Wastewater Discharge Permit Issuance](#)

[Subdivision VI. - Reporting Requirements](#)

[Subdivision VII. - Compliance Monitoring](#)

[Subdivision VIII. - Confidential Information](#)

[Subdivision IX. - Publication of Users in Significant Noncompliance](#)

[Subdivision X. - Administrative Enforcement Remedies](#)

[Subdivision XI. - Judicial Enforcement Remedies](#)

[Subdivision XII. - Supplemental Enforcement Action](#)

[Subdivision XIII. - Affirmative Defenses to Discharge Violations](#)

[Subdivision XIV. - Wastewater Treatment Rates\(Reserved\)](#)

[Subdivision XV. - Miscellaneous Provisions](#)

- CODE OF ORDINANCES
Chapter 14 - WATER AND SEWERS
ARTICLE III. - SEWERS
DIVISION 5. - PRETREATMENT

Subdivision I. General Provisions

Subdivision I. General Provisions

[Sec. 14-140. Purpose and policy.](#)

[Sec. 14-141. Administration.](#)

[Sec. 14-142. Abbreviations.](#)

[Sec. 14-143. Definitions.](#)

[Secs. 14-144—14-154. Reserved.](#)

Sec. 14-140. Purpose and policy.

This division sets forth uniform requirements for users of the publicly owned treatment works for the city and enables the city to comply with all applicable state and federal laws, including the state pretreatment requirements (Missouri 10 CSR 20-6.100), the Clean Water Act (33 United States Code [U.S.C.] section 1251 et seq.) and the General Pretreatment Regulations (Title 40 of the Code of Federal Regulations [CFR] Part 403). The objectives of this division are:

- (a) To prevent the introduction of pollutants into the publicly owned treatment works that will interfere with its operation;
- (b) To prevent the introduction of pollutants into the publicly owned treatment works that will pass through the publicly owned treatment works, inadequately treated, into receiving waters, or otherwise be incompatible with the publicly owned treatment works;
- (c) To protect both publicly owned treatment works personnel who may be affected by wastewater and sludge in the course of their employment and the general public;
- (d) To promote reuse and recycling of industrial wastewater and sludge from the publicly owned treatment works;
- (e) To enable the city to comply with its National Pollutant Discharge Elimination System permit conditions, sludge use and disposal requirements, and any other federal or state laws to which the publicly owned treatment works is subject.

This division shall apply to all users of the publicly owned treatment works. The division authorizes the issuance of individual wastewater discharge permits; provides for monitoring, compliance, and enforcement activities; establishes administrative review procedures; requires user reporting; and provides for the setting of fees for the equitable distribution of costs resulting from the program established herein.

(Ord. No. 4110, § 2(1.1), 6-8-09)

Sec. 14-141. Administration.

Except as otherwise provided herein, the city manager shall administer, implement, and enforce the provisions of this division. Any powers granted to or duties imposed upon the city manager may be delegated by the city manager to a duly authorized city employee or representative.

(Ord. No. 4110, § 2(1.2), 6-8-09)

- CODE OF ORDINANCES
 Chapter 14 - WATER AND SEWERS
 ARTICLE III. - SEWERS
 DIVISION 5. - PRETREATMENT

Subdivision I. General Provisions

Sec. 14-142. Abbreviations.

The following abbreviations, when used in this division, shall have the designated meanings:

BOD	—	Biochemical oxygen demand
BMP	—	Best management practice
BMR	—	Baseline monitoring report
CFR	—	Code of Federal Regulations
CIU	—	Categorical industrial user
COD	—	Chemical oxygen demand
EPA	—	U.S. Environmental Protection Agency
gpd	—	Gallons per day
IU	—	Industrial user
mg/l	—	milligrams per liter
NPDES	—	National Pollutant Discharge Elimination System
POTW	—	Publicly owned treatment works
RCRA	—	Resource Conservation and Recovery Act
SIU	—	Significant industrial user
SNC	—	Significant noncompliance
TSS	—	Total suspended solids
U.S.C.	—	United States Code

- CODE OF ORDINANCES
Chapter 14 - WATER AND SEWERS
ARTICLE III. - SEWERS
DIVISION 5. - PRETREATMENT

Subdivision I. General Provisions

(Ord. No. 4110, § 2(1.3), 6-8-09)

Sec. 14-143. Definitions.

Unless a provision explicitly states otherwise, the following terms and phrases, as used in this division, shall have the meanings hereinafter designated.

Act or the Act. The Federal Water Pollution Control Act, also known as the Clean Water Act, as amended, 33 U.S.C. section 1251 et seq.

Approval authority. The Missouri Department of Natural Resources director or his/her representative(s).

Authorized or duly authorized representative of the user.

(1) If the user is a corporation:

- a. The president, secretary, treasurer, or a vice president of the corporation in charge of a principal business function, or any other person who performs similar policy or decision-making functions for the corporation; or
- b. The manager of one (1) or more manufacturing, production, or operating facilities, provided the manager is authorized to make management decisions that govern the operation of the regulated facility including having the explicit or implicit duty of making major capital investment recommendations, and initiate and direct other comprehensive measures to assure longterm environmental compliance with environmental laws and regulations; can ensure that the necessary systems are established or actions taken to gather complete and accurate information for individual wastewater discharge permit requirements; and where authority to sign documents has been assigned or delegated to the manager in accordance with corporate procedures.

(2) If the user is a partnership or sole proprietorship: a general partner or proprietor, respectively.

(3) If the user is a federal, state, or local governmental facility: a director or highest official appointed or designated to oversee the operation and performance of the activities of the government facility, or their designee.

(4) The individuals described in subsections (1) through (3), above, may designate a duly authorized representative if the authorization is in writing, the authorization specifies the individual or position responsible for the overall operation of the facility from which the discharge originates or having overall responsibility for environmental matters for the company, and the written authorization is submitted to the city.

Best management practices or BMPs. Schedules of activities, prohibitions of practices, maintenance procedures, and other management practices to implement the prohibitions listed in subsections [14-155\(a\)](#) and (b). BMPs include treatment requirements, operating procedures, and practices to control plant site runoff, spillage or leaks, sludge or waste disposal, or drainage from raw materials storage.

Biochemical oxygen demand or BOD. The quantity of oxygen utilized in the biochemical oxidation of organic matter under standard laboratory procedures for five (5) days at twenty (20) degrees centigrade, usually expressed as a concentration (e.g., mg/l).

- CODE OF ORDINANCES
Chapter 14 - WATER AND SEWERS
ARTICLE III. - SEWERS
DIVISION 5. - PRETREATMENT

Subdivision I. General Provisions

Categorical pretreatment standard or categorical standard. Any regulation containing pollutant discharge limits promulgated by the EPA in accordance with sections 307(b) and (c) of the Act (33 U.S.C. section 1317) that apply to a specific category of users and that appear in 40 CFR chapter I, subchapter N, parts 405-471.

Categorical industrial user. An industrial user subject to a categorical pretreatment standard or categorical standard.

City. The City of Mexico, Missouri.

Chemical oxygen demand or COD. A measure of the oxygen required to oxidize all compounds, both organic and inorganic, in water.

Control authority. The city.

Daily maximum. The arithmetic average of all effluent samples for a pollutant (except pH) collected during a calendar day.

Daily maximum limit. The maximum allowable discharge limit of a pollutant during a calendar day. Where daily maximum limits are expressed in units of mass, the daily discharge is the total mass discharged over the course of the day. Where daily maximum limits are expressed in terms of a concentration, the daily discharge is the arithmetic average measurement of the pollutant concentration derived from all measurements taken that day.

Environmental Protection Agency or EPA. The U.S. Environmental Protection Agency or, where appropriate, the regional water management division director, the regional administrator, or other duly authorized official of said agency.

Existing source. Any source of discharge that is not a "new source."

Grab sample. A sample that is taken from a wastestream without regard to the flow in the wastestream and over a period of time not to exceed fifteen (15) minutes.

Indirect discharge or discharge. The introduction of pollutants into the POTW from any nondomestic source.

Instantaneous limit. The maximum concentration of a pollutant allowed to be discharged at any time, determined from the analysis of any discrete or composited sample collected, independent of the industrial flow rate and the duration of the sampling event.

Interference. A discharge that, alone or in conjunction with a discharge or discharges from other sources, inhibits or disrupts the POTW, its treatment processes or operations or its sludge processes, use or disposal; and therefore, is a cause of a violation of the city's NPDES permit or of the prevention of sewage sludge use or disposal in compliance with any of the following statutory/regulatory provisions or permits issued thereunder, or any more stringent state or local regulations: section 405 of the Act; the Solid Waste Disposal Act, including title II commonly referred to as the Resource Conservation and Recovery Act (RCRA); any state regulations contained in any state sludge management plan prepared pursuant to subtitle D of the Solid Waste Disposal Act; the Clean Air Act; the Toxic Substances Control Act; and the Marine Protection, Research, and Sanctuaries Act.

Local limit. Specific discharge limits developed and enforced by the city upon industrial or commercial facilities to implement the general and specific discharge prohibitions listed in Missouri 10 CSR 20-6.100.

Medical waste. Isolation wastes, infectious agents, human blood and blood products, pathological wastes, sharps, body parts, contaminated bedding, surgical wastes, potentially contaminated laboratory wastes, and dialysis wastes.

- CODE OF ORDINANCES
Chapter 14 - WATER AND SEWERS
ARTICLE III. - SEWERS
DIVISION 5. - PRETREATMENT

Subdivision I. General Provisions

Monthly average. The sum of all "daily discharges" measured during a calendar month divided by the number of "daily discharges" measured during that month.

Monthly average limit. The highest allowable average of "daily discharges" over a calendar month, calculated as the sum of all "daily discharges" measured during a calendar month divided by the number of "daily discharges" measured during that month.

New source.

- (1) Any building, structure, facility, or installation from which there is (or may be) a discharge of pollutants, the construction of which commenced after the publication of proposed pretreatment standards under section 307(c) of the Act that will be applicable to such source if such standards are thereafter promulgated in accordance with that section, provided that:
 - a. The building, structure, facility, or installation is constructed at a site at which no other source is located; or
 - b. The building, structure, facility, or installation totally replaces the process or production equipment that causes the discharge of pollutants at an existing source; or
 - c. The production or wastewater generating processes of the building, structure, facility, or installation are substantially independent of an existing source at the same site. In determining whether these are substantially independent, factors such as the extent to which the new facility is integrated with the existing plant, and the extent to which the new facility is engaged in the same general type of activity as the existing source, should be considered.
- (2) Construction on a site at which an existing source is located results in a modification rather than a new source if the construction does not create a new building, structure, facility, or installation meeting the criteria of subsection (1)(b) or (c) above but otherwise alters, replaces, or adds to existing process or production equipment.
- (3) Construction of a new source as defined under this paragraph has commenced if the owner or operator has:
 - a. Begun, or caused to begin, as part of a continuous onsite construction program:
 - (i) Any placement, assembly, or installation of facilities or equipment; or
 - (ii) Significant site preparation work including clearing, excavation, or removal of existing buildings, structures, or facilities which is necessary for the placement, assembly, or installation of new source facilities or equipment; or
 - b. Entered into a binding contractual obligation for the purchase of facilities or equipment which are intended to be used in its operation within a reasonable time. Options to purchase or contracts which can be terminated or modified without substantial loss, and contracts for feasibility, engineering, and design studies do not constitute a contractual obligation under this paragraph.

Noncontact cooling water. Water used for cooling that does not come into direct contact with any raw material, intermediate product, waste product, or finished product.

Pass through. A discharge which exits the POTW into waters of the United States in quantities or concentrations which, alone or in conjunction with a discharge or discharges from other sources, is a cause of a violation of any requirement of the city's NPDES permit, including an increase in the magnitude or duration of a violation.

- CODE OF ORDINANCES
Chapter 14 - WATER AND SEWERS
ARTICLE III. - SEWERS
DIVISION 5. - PRETREATMENT

Subdivision I. General Provisions

Person. Any and all persons, including individuals, firms, partnerships, association, public or private institutions, state and federal agencies, municipalities or political subdivisions, or officers thereof, departments, agencies, or instrumentalities, or public or private corporations or officers thereof, organized or existing under the laws of this or any state or country.

pH. A measure of the acidity or alkalinity of a solution, expressed in standard units.

Pollutant. Dredged spoil, solid waste, incinerator residue, filter backwash, sewage, garbage, sewage sludge, munitions, medical wastes, chemical wastes, biological materials, radioactive materials, heat, wrecked or discarded equipment, rock, sand, cellar dirt, municipal, agricultural and industrial wastes, and certain characteristics of wastewater (e.g., pH, temperature, TSS, turbidity, color, BOD, COD, toxicity, or odor).

Pretreatment. The reduction of the amount of pollutants, the elimination of pollutants, or the alteration of the nature of pollutant properties in wastewater prior to, or in lieu of, introducing such pollutants into the POTW. This reduction or alteration can be obtained by physical, chemical, or biological processes; by process changes; or by other means, except by diluting the concentration of the pollutants unless allowed by an applicable pretreatment standard.

Pretreatment requirements. Any substantive or procedural requirement related to pretreatment imposed on a user, other than a pretreatment standard.

Pretreatment standards or standards. Pretreatment standards shall mean prohibited discharge standards, categorical pretreatment standards, and local limits.

Prohibited discharge standards or prohibited discharges. Absolute prohibitions against the discharge of certain substances; these prohibitions appear in [section 14-155](#).

Publicly owned treatment works or POTW. A treatment works, as defined by section 212 of the Act (33 U.S.C. section 1292), which is owned by the city. This definition includes any devices or systems used in the collection, storage, treatment, recycling, and reclamation of sewage or industrial wastes of a liquid nature and any conveyances, which convey wastewater to a treatment plant.

Septic tank waste. Any sewage from holding tanks such as vessels, chemical toilets, campers, trailers, and septic tanks.

Sewage. Human excrement and gray water (household showers, dishwashing operations, etc.).

Significant industrial user (SIU). Except as provided in subdivisions III and IV, a significant industrial user is:

- (1) An industrial user subject to categorical pretreatment standards; or
- (2) An industrial user that:
 - (a) Discharges an average of twenty-five thousand (25,000) gpd or more of process wastewater to the POTW (excluding sanitary, noncontact cooling and boiler blowdown wastewater);
 - (b) Contributes a process wastestream which makes up five (5) percent or more of the average dry weather hydraulic or organic capacity of the POTW treatment plant; or
 - (c) Is designated as such by the city on the basis that it has a reasonable potential for adversely affecting the POTW's operation or for violating any pretreatment standard or requirement.

Slug load or slug discharge. Any discharge at a flow rate or concentration, which could cause a violation of the prohibited discharge standards in [section 14-155](#). A slug discharge is any discharge of a

- CODE OF ORDINANCES
Chapter 14 - WATER AND SEWERS
ARTICLE III. - SEWERS
DIVISION 5. - PRETREATMENT

Subdivision I. General Provisions

nonroutine, episodic nature, including, but not limited to, an accidental spill or a noncustomary batch discharge, which has a reasonable potential to cause interference or pass through, or in any other way violate the POTW's regulations, local limits or permit conditions.

Stormwater. Any flow occurring during or following any form of natural precipitation, and resulting from such precipitation, including snowmelt.

City manager. The person designated by the city to supervise the operation of the POTW, and who is charged with certain duties and responsibilities by this division. The term also means a duly authorized representative of the city manager.

Total suspended solids or suspended solids. The total suspended matter that floats on the surface of, or is suspended in, water, wastewater, or other liquid, and that is removable by laboratory filtering.

User or industrial user. A source of indirect discharge.

Wastewater. Liquid and water-carried industrial wastes and sewage from residential dwellings, commercial buildings, industrial and manufacturing facilities, and institutions, whether treated or untreated, which are contributed to the POTW.

Wastewater treatment plant or treatment plant. That portion of the POTW which is designed to provide treatment of municipal sewage and industrial waste.

(Ord. No. 4110, § 2(1.4), 6-8-09)

Secs. 14-144—14-154. Reserved.

- CODE OF ORDINANCES
Chapter 14 - WATER AND SEWERS
ARTICLE III. - SEWERS
DIVISION 5. - PRETREATMENT

Subdivision II. General Sewer Use Requirements

Subdivision II. General Sewer Use Requirements

[Sec. 14-155. Prohibited discharge standards.](#)

[Sec. 14-156. National categorical pretreatment standards.](#)

[Sec. 14-157. State pretreatment standards.](#)

[Sec. 14-158. Local limits.](#)

[Sec. 14-159. City's right of revision.](#)

[Sec. 14-160. Dilution.](#)

[Secs. 14-161—14-174. Reserved.](#)

Sec. 14-155. Prohibited discharge standards.

- (a) *General prohibitions.* No user shall introduce or cause to be introduced into the POTW any pollutant or wastewater which causes pass through or interference. These general prohibitions apply to all users of the POTW whether or not they are subject to categorical pretreatment standards or any other national, state, or local pretreatment standards or requirements.
- (b) *Specific prohibitions.* No user shall introduce or cause to be introduced into the POTW the following pollutants, substances, or wastewater:
- (1) Pollutants which create a fire or explosive hazard in the POTW, including, but not limited to, wastestreams with a closed-cup flashpoint of less than one hundred forty (140) degrees F (sixty (60) degrees C) using the test methods specified in 40 CFR 261.21;
 - (2) Wastewater having a pH less than 5.0 or more than 10.0, or otherwise causing corrosive structural damage to the POTW or equipment;
 - (3) Solid or viscous substances in amounts which will cause obstruction of the flow in the POTW resulting in interference;
 - (4) Pollutants, including oxygen-demanding pollutants (BOD, etc.), released in a discharge at a flow rate and/or pollutant concentration which, either singly or by interaction with other pollutants, will cause interference with the POTW;
 - (5) Wastewater having a temperature greater than one hundred fifty (150) degrees F (sixty-five (65) degrees C), or which will inhibit biological activity in the treatment plant resulting in interference, but in no case wastewater which causes the temperature at the introduction into the treatment plant to exceed one hundred four (104) degrees F (forty (40) degrees C);
 - (6) Petroleum oil, nonbiodegradable cutting oil, or products of mineral oil origin, in amounts that will cause interference or pass through;
 - (7) Pollutants which result in the presence of toxic gases, vapors, or fumes within the POTW in a quantity that may cause acute worker health and safety problems;
 - (8) Trucked or hauled pollutants, except at discharge points designated by the city manager in accordance with [section 14-178](#)

- CODE OF ORDINANCES
Chapter 14 - WATER AND SEWERS
ARTICLE III. - SEWERS
DIVISION 5. - PRETREATMENT

Subdivision II. General Sewer Use Requirements

- (9) Noxious or malodorous liquids, gases, solids, or other wastewater which, either singly or by interaction with other wastes, are sufficient to create a public nuisance or a hazard to life, or to prevent entry into the sewers for maintenance or repair;
- (10) Wastewater which imparts color which cannot be removed by the treatment process, such as, but not limited to, dye wastes and vegetable tanning solutions, which consequently imparts color to the treatment plant's effluent, thereby violating the city's NPDES permit;
- (11) Wastewater containing any radioactive wastes or isotopes except in compliance with applicable state or federal regulations;
- (12) Stormwater, surface water, groundwater, artesian well water, roof runoff, subsurface drainage, swimming pool drainage, condensate, deionized water, noncontact cooling water, and unpolluted wastewater, unless specifically authorized by the city manager;
- (13) Sludges, screenings, or other residues from the pretreatment of industrial wastes;
- (14) Medical wastes, except as specifically authorized by the city manager in an individual wastewater discharge permit;
- (15) Wastewater causing, alone or in conjunction with other sources, the treatment plant's effluent to fail toxicity test;
- (16) Detergents, surface-active agents, or other substances which that might cause excessive foaming in the POTW;
- (17) Fats, oils, or greases of animal or vegetable origin in concentrations greater than one hundred (100) mg/l.

Pollutants, substances, or wastewater prohibited by this section shall not be processed or stored in such a manner that they could be directly discharged to the POTW.

(Ord. No. 4110, § 2(2.1), 6-8-09)

Sec. 14-156. National categorical pretreatment standards.

Users must comply with the categorical pretreatment standards found at 40 CFR chapter I, subchapter N, parts 405—471.

- (a) Where a categorical pretreatment standard is expressed only in terms of either the mass or the concentration of a pollutant in wastewater, the city manager may impose equivalent concentration or mass limits in accordance with subsections (e) and (f).
- (b) When the limits in a categorical pretreatment standard are expressed only in terms of mass of pollutant per unit of production, the city manager may convert the limits to equivalent limitations expressed either as mass of pollutant discharged per day or effluent concentration for purposes of calculating effluent limitations applicable to individual industrial users.
- (c) When wastewater subject to a categorical pretreatment standard is mixed with wastewater not regulated by the same standard, the city manager shall impose an alternate limit in accordance with Missouri 10 CSR 20-6.100.
- (d) Once included in its permit, the industrial user must comply with the equivalent limitations developed in this section in lieu of the promulgated categorical standards from which the equivalent limitations were derived.

- CODE OF ORDINANCES
 Chapter 14 - WATER AND SEWERS
 ARTICLE III. - SEWERS
 DIVISION 5. - PRETREATMENT

Subdivision II. General Sewer Use Requirements

- (e) Many categorical pretreatment standards specify one (1) limit for calculating maximum daily discharge limitations and a second limit for calculating maximum monthly average, or four-day average, limitations. Where such standards are being applied, the same production or flow figure shall be used in calculating both the average and the maximum equivalent limitation.
- (f) Any industrial user operating under a permit incorporating equivalent mass or concentration limits calculated from a production-based standard shall notify the city manager within two (2) business days after the user has a reasonable basis to know that the production level will significantly change within the next calendar month. Any user not notifying the city manager of such anticipated change will be required to meet the mass or concentration limits in its permit that were based on the original estimate of the long term average production rate.

(Ord. No. 4110, § 2(2.2), 6-8-09)

Sec. 14-157. State pretreatment standards.

Users must comply with Missouri's pretreatment standards codified at 10 CSR 20-6.100.

(Ord. No. 4110, § 2(2.3), 6-8-09)

Sec. 14-158. Local limits.

- (a) The city manager is authorized to establish local limits pursuant to Missouri 10 CSR 20-6.100.
- (b) The following pollutant limits are established to protect against pass through and interference. No person shall discharge wastewater containing in excess of the following daily maximum limit without explicit written limit modifications within an individual industrial wastewater permit issued by the city. (Limits apply to average concentration of all samples collected during the averaging period.)

25 mg/l	Ammonia
0.02 mg/l	Arsenic
225 mg/l	BOD ₅
0.15 mg/l	Cadmium
3.50 mg/l	Chromium (as total chromium)
1.00 mg/l	Copper
2 mg/l	Cyanide
1.00 mg/l	Lead

- CODE OF ORDINANCES
 Chapter 14 - WATER AND SEWERS
 ARTICLE III. - SEWERS
 DIVISION 5. - PRETREATMENT

Subdivision II. General Sewer Use Requirements

0.10 mg/l	Mercury
25.0 mg/l	Nitrogen (as ammonia)
2.00 mg/l	Nickel
100 mg/l	Total fat, oil and/or grease
0.05 mg/l	Selenium
0.02 mg/l	Silver
10 mg/l	Total phenols
300 mg/l	Total suspended solids
15.00 mg/l	Zinc

The above limits apply at the point where the wastewater is discharged to the POTW. All concentrations for metallic substances are for total metal unless indicated otherwise. The city manager may impose mass limitations in addition to the concentration-based limitations above.

(Ord. No. 4110, § 2(2.4), 6-8-09)

Sec. 14-159. City's right of revision.

The city reserves the right to establish, by ordinance or in individual wastewater discharge permits, more stringent standards or requirements on discharges to the POTW consistent with the purpose of this division.

(Ord. No. 4110, § 2(2.5), 6-8-09)

Sec. 14-160. Dilution.

No user shall ever increase the use of process water, or in any way attempt to dilute a discharge, as a partial or complete substitute for adequate treatment to achieve compliance with a discharge limitation unless expressly authorized by an applicable pretreatment standard or requirement. The city manager may impose mass limitations on users who are using dilution to meet applicable pretreatment standards or requirements, or in other cases when the imposition of mass limitations is appropriate.

- CODE OF ORDINANCES
Chapter 14 - WATER AND SEWERS
ARTICLE III. - SEWERS
DIVISION 5. - PRETREATMENT

Subdivision II. General Sewer Use Requirements

(Ord. No. 4110, § 2(2.6), 6-8-09)

Secs. 14-161—14-174. Reserved.

- CODE OF ORDINANCES
Chapter 14 - WATER AND SEWERS
ARTICLE III. - SEWERS
DIVISION 5. - PRETREATMENT

Subdivision III. Pretreatment of Wastewater

Subdivision III. Pretreatment of Wastewater

[Sec. 14-175. Pretreatment facilities.](#)

[Sec. 14-176. Additional pretreatment measures.](#)

[Sec. 14-177. Accidental discharge/slug discharge control plans.](#)

[Sec. 14-178. Hauled wastewater.](#)

[Secs. 14-179—14-194. Reserved.](#)

Sec. 14-175. Pretreatment facilities.

Users shall provide wastewater treatment as necessary to comply with this division and shall achieve compliance with all categorical pretreatment standards, local limits, and the prohibitions set out in [section 14-155](#) within the time limitations specified by EPA, the state, or the city manager, whichever is more stringent. Any facilities necessary for compliance shall be provided, operated, and maintained at the user's expense. Detailed plans describing such facilities and operating procedures shall be submitted to the city manager for review, and shall be acceptable to the city manager before such facilities are constructed. The review of such plans and operating procedures shall in no way relieve the user from the responsibility of modifying such facilities as necessary to produce a discharge acceptable to the city under the provisions of this division.

(Ord. No. 4110, § 2(3.1), 6-8-09)

Sec. 14-176. Additional pretreatment measures.

- (a) Whenever deemed necessary, the city manager may require users to restrict their discharge during peak flow periods, designate that certain wastewater be discharged only into specific sewers, relocate and/or consolidate points of discharge, separate sewage wastestreams from industrial wastestreams, and such other conditions as may be necessary to protect the POTW and determine the user's compliance with the requirements of this division.
- (b) The city manager may require any person discharging into the POTW to install and maintain, on their property and at their expense, a suitable storage and flow-control facility to ensure equalization of flow. An individual wastewater discharge permit may be issued solely for flow equalization.
- (c) Grease, oil, and sand interceptors shall be provided when, in the opinion of the city manager, they are necessary for the proper handling of wastewater containing excessive amounts of grease and oil, or sand; except that such interceptors shall not be required for residential users. All interception units shall be of a type and capacity approved by the city manager, shall comply with [section 14-58](#) of the City Code and shall be so located to be easily accessible for cleaning and inspection. Such interceptors shall be inspected, cleaned, and repaired in accordance with [section 14-58](#) of the City Code by the user at their expense.
- (d) Users with the potential to discharge flammable substances may be required to install and maintain an approved combustible gas detection meter.

(Ord. No. 4110, § 2(3.2), 6-8-09)

- CODE OF ORDINANCES
Chapter 14 - WATER AND SEWERS
ARTICLE III. - SEWERS
DIVISION 5. - PRETREATMENT

Subdivision III. Pretreatment of Wastewater

Sec. 14-177. Accidental discharge/slug discharge control plans.

The city manager shall evaluate whether each SIU needs an accidental discharge/slug discharge control plan or other action to control slug discharges. The city manager may require any user to develop, submit for approval, and implement such a plan or take such other action that may be necessary to control slug discharges. Alternatively, the city manager may develop such a plan for any user. An accidental discharge/slug discharge control plan shall address, at a minimum, the following:

- (a) Description of discharge practices, including nonroutine batch discharges;
- (b) Description of stored chemicals;
- (c) Procedures for immediately notifying the city manager of any accidental or slug discharge, as required by [section 14-250](#); and
- (d) Procedures to prevent adverse impact from any accidental or slug discharge. Such procedures include, but are not limited to, inspection and maintenance of storage areas, handling and transfer of materials, loading and unloading operations, control of plant site runoff, worker training, building of containment structures or equipment, measures for containing toxic organic pollutants, including solvents, and/or measures and equipment for emergency response.

(Ord. No. 4110, § 2(3.3), 6-8-09)

Sec. 14-178. Hauled wastewater.

- (a) Septic tank waste may be introduced into the POTW only at locations designated by the city manager, and at such times as are established by the city manager. Such waste shall not violate subdivision II or any other requirements established by the city. The city manager may require septic tank waste haulers to obtain individual wastewater discharge permits.
- (b) The city manager may require haulers of industrial waste to obtain individual wastewater discharge permits. The city manager may require generators of hauled industrial waste to obtain individual wastewater discharge permits. The city manager also may prohibit the disposal of hauled industrial waste. The discharge of hauled industrial waste is subject to all other requirements of this division.
- (c) Industrial waste haulers may discharge loads only at locations designated by the city manager. No load may be discharged without prior consent of the city manager. The city manager may collect samples of each hauled load to ensure compliance with applicable standards. The city manager may require the industrial waste hauler to provide a waste analysis of any load prior to discharge.
- (d) Industrial waste haulers must provide a waste-tracking form for every load. This form shall include, at a minimum, the name and address of the industrial waste hauler, permit number, truck identification, names and addresses of sources of waste, and volume and characteristics of waste. The form shall identify the type of industry, known or suspected waste constituents, and whether any wastes are RCRA hazardous wastes.

(Ord. No. 4110, § 2(3.4), 6-8-09)

Secs. 14-179—14-194. Reserved.

- CODE OF ORDINANCES
Chapter 14 - WATER AND SEWERS
ARTICLE III. - SEWERS
DIVISION 5. - PRETREATMENT

Subdivision IV. Individual Wastewater Discharge Permits

Subdivision IV. Individual Wastewater Discharge Permits

[Sec. 14-195. Wastewater analysis.](#)

[Sec. 14-196. Individual wastewater discharge permit requirement.](#)

[Sec. 14-197. Individual wastewater discharge permitting: existing connections.](#)

[Sec. 14-198. Individual wastewater discharge permitting: new connections.](#)

[Sec. 14-199. Individual wastewater discharge permit application contents.](#)

[Sec. 14-200. Application signatories and certifications.](#)

[Sec. 14-201. Individual wastewater discharge permit decisions.](#)

[Secs. 14-202—14-224. Reserved.](#)

Sec. 14-195. Wastewater analysis.

When requested by the city manager, a user must submit information on the nature and characteristics of its wastewater within thirty (30) days of the request. The city manager is authorized to prepare a form for this purpose and may periodically require users to update this information.

(Ord. No. 4110, § 2(4.1), 6-8-09)

Sec. 14-196. Individual wastewater discharge permit requirement.

- (a) No significant industrial user shall discharge wastewater into the POTW without first obtaining an individual wastewater discharge permit from the city manager, except that a significant industrial user that has filed a timely application pursuant to [section 14-197](#) may continue to discharge for the time period specified therein.
- (b) The city manager may require other users to obtain individual wastewater discharge permits as necessary to carry out the purposes of this division.
- (c) Any violation of the terms and conditions of an individual wastewater discharge permit shall be deemed a violation of this division and subjects the wastewater discharge permittee to the sanctions set out in subdivisions X through XII. Obtaining an individual wastewater discharge permit does not relieve a permittee of its obligation to comply with all federal and state pretreatment standards or requirements or with any other requirements of federal, state, and local law.

(Ord. No. 4110, § 2(4.2), 6-8-09)

Sec. 14-197. Individual wastewater discharge permitting: existing connections.

Any user required to obtain an individual wastewater discharge permit who was discharging wastewater into the POTW prior to the effective date of this division [June 8, 2009] and who wishes to continue such discharges in the future, shall, within thirty (30) days after said date, apply to the city manager for an individual wastewater discharge permit in accordance with [section 14-199](#). The user shall

- CODE OF ORDINANCES
Chapter 14 - WATER AND SEWERS
ARTICLE III. - SEWERS
DIVISION 5. - PRETREATMENT

Subdivision IV. Individual Wastewater Discharge Permits

not cause or allow discharges to the POTW to continue after ninety (90) days of the effective date of this division except in accordance with an individual wastewater discharge permit issued by the city manager.

(Ord. No. 4110, § 2(4.3), 6-8-09)

Sec. 14-198. Individual wastewater discharge permitting: new connections.

Any user required to obtain an individual wastewater discharge permit who proposes to begin or recommence discharging into the POTW must obtain such permit prior to the beginning or recommencing of such discharge. An application for this individual wastewater discharge permit, in accordance with [section 14-199](#), must be filed at least ninety (90) days prior to the date upon which any discharge will begin or recommence.

(Ord. No. 4110, § 2(4.4), 6-8-09)

Sec. 14-199. Individual wastewater discharge permit application contents.

- (a) All users required to obtain an individual wastewater discharge permit must submit a permit application. The city manager may require users to submit all or some of the following information as part of a permit application:
- (1) *Identifying information.*
 - a. The name and address of the facility, including the name of the operator and owner.
 - b. Contact information, description of activities, facilities, and plant production processes on the premises.
 - (2) *Environmental permits.* A list of any environmental control permits held by or for the facility.
 - (3) *Description of operations.*
 - a. A brief description of the nature, average rate of production (including each product produced by type, amount, processes, and rate of production), and standard industrial classifications of the operation(s) carried out by such user. This description should include a schematic process diagram, which indicates points of discharge to the POTW from the regulated processes.
 - b. Types of wastes generated, and a list of all raw materials and chemicals used or stored at the facility which are, or could accidentally or intentionally be, discharged to the POTW.
 - c. Number and type of employees, hours of operation, and proposed or actual hours of operation.
 - d. Type and amount of raw materials processed (average and maximum per day).
 - e. Site plans, floor plans, mechanical and plumbing plans, and details to show all sewers, floor drains, and appurtenances by size, location, and elevation, and all points of discharge.
 - (4) *Time and duration of discharges.*
 - (5) *[Monitoring.]* The location for monitoring all wastes covered by the permit.

- CODE OF ORDINANCES
Chapter 14 - WATER AND SEWERS
ARTICLE III. - SEWERS
DIVISION 5. - PRETREATMENT

Subdivision IV. Individual Wastewater Discharge Permits

- (6) *Flow measurement.* Information showing the measured average daily and maximum daily flow, in gallons per day, to the POTW from regulated process streams and other streams, as necessary, to allow use of the combined wastestream formula set out in subsection [14-156\(c\)](#).
- (7) *Measurement of pollutants.*
- a. The categorical pretreatment standards applicable to each regulated process and any new categorically regulated processes for existing sources.
 - b. The results of sampling and analysis identifying the nature and concentration, and/or mass, where required by the standard or by the city manager, of regulated pollutants in the discharge from each regulated process.
 - c. Instantaneous, daily maximum, and longterm average concentrations, or mass, where required, shall be reported.
 - d. The sample shall be representative of daily operations and shall be analyzed in accordance with procedures set out in [section 14-254](#). Where the standard requires compliance with a BMP or pollution prevention alternative, the user shall submit documentation as required by the city manager or the applicable standards to determine compliance with the standard.
 - e. Sampling must be performed in accordance with procedures set out in [section 14-255](#)
- (8) *[Additional required information.]* Any other information as may be deemed necessary by the city manager to evaluate the permit application.
- (b) Incomplete or inaccurate applications will not be processed and will be returned to the user for revision.

(Ord. No. 4110, § 2(4.5), 6-8-09)

Sec. 14-200. Application signatories and certifications.

- (a) All wastewater discharge permit applications, user reports and certification statements must be signed by an authorized representative of the user and contain the certification statement in [section 14-258](#)
- (b) If the designation of an authorized representative is no longer accurate because a different individual or position has responsibility for the overall operation of the facility or overall responsibility for environmental matters for the company, a new written authorization satisfying the requirements of this section must be submitted to the city manager prior to or together with any reports to be signed by an authorized representative.

(Ord. No. 4110, § 2(4.6), 6-8-09)

Sec. 14-201. Individual wastewater discharge permit decisions.

The city manager will evaluate the data furnished by the user and may require additional information. Within forty-five (45) days of receipt of a complete permit application, the city manager will determine whether to issue an individual wastewater discharge permit. The city manager may deny any application for an individual wastewater discharge permit.

(Ord. No. 4110, § 2(4.7), 6-8-09)

- CODE OF ORDINANCES
Chapter 14 - WATER AND SEWERS
ARTICLE III. - SEWERS
DIVISION 5. - PRETREATMENT

Subdivision IV. Individual Wastewater Discharge Permits

Secs. 14-202—14-224. Reserved.

- CODE OF ORDINANCES
Chapter 14 - WATER AND SEWERS
ARTICLE III. - SEWERS
DIVISION 5. - PRETREATMENT

Subdivision V. Individual Wastewater Discharge Permit Issuance

Subdivision V. Individual Wastewater Discharge Permit Issuance

[Sec. 14-225. Individual wastewater discharge permit duration.](#)

[Sec. 14-226. Individual wastewater discharge permit contents.](#)

[Sec. 14-227. Permit issuance process, appeals.](#)

[Sec. 14-228. Permit modification.](#)

[Sec. 14-229. Individual wastewater discharge permit transfer.](#)

[Sec. 14-230. Individual wastewater discharge permit revocation.](#)

[Sec. 14-231. Individual wastewater discharge permit reissuance.](#)

[Secs. 14-232—14-244. Reserved.](#)

Sec. 14-225. Individual wastewater discharge permit duration.

An individual wastewater discharge permit shall be issued for a specified time period, not to exceed five (5) years from the effective date of the permit. An individual wastewater discharge permit may be issued for a period less than five (5) years, at the discretion of the city manager. Each individual wastewater discharge permit will indicate a specific date upon which it will expire.

(Ord. No. 4110, § 2(5.1), 6-8-09)

Sec. 14-226. Individual wastewater discharge permit contents.

An individual wastewater discharge permit shall include such conditions as are deemed reasonably necessary by the city manager to prevent pass through or interference, protect the quality of the water body receiving the treatment plant's effluent, protect worker health and safety, facilitate sludge management and disposal, and protect against damage to the POTW.

(a) Individual wastewater discharge permits must contain:

- (1) A statement that indicates the wastewater discharge permit issuance date, expiration date and effective date;
- (2) A statement that the wastewater discharge permit is nontransferable without prior notification to the city in accordance with [section 14-229](#), and provisions for furnishing the new owner or operator with a copy of the existing wastewater discharge permit;
- (3) Effluent limits, including best management practices, based on applicable pretreatment standards;
- (4) Self monitoring, sampling, reporting, notification, and recordkeeping requirements. These requirements shall include an identification of pollutants (or best management practice) to be monitored, sampling location, sampling frequency, and sample type based on federal, state, and local law;
- (5) A statement of applicable civil and criminal penalties for violation of pretreatment standards and requirements, and any applicable compliance schedule. Such schedule may not

- CODE OF ORDINANCES
Chapter 14 - WATER AND SEWERS
ARTICLE III. - SEWERS
DIVISION 5. - PRETREATMENT

Subdivision V. Individual Wastewater Discharge Permit Issuance

extend the time for compliance beyond that required by applicable federal, state, or local law;

- (6) Requirements to control slug discharge, if determined by the city manager to be necessary.
- (b) Individual wastewater discharge permits may contain, but need not be limited to, the following conditions:
- (1) Limits on the average and/or maximum rate of discharge, time of discharge, and/or requirements for flow regulation and equalization;
 - (2) Requirements for the installation of pretreatment technology, pollution control, or construction of appropriate containment devices, designed to reduce, eliminate, or prevent the introduction of pollutants into the treatment works;
 - (3) Requirements for the development and implementation of spill control plans or other special conditions including management practices necessary to adequately prevent accidental, unanticipated, or nonroutine discharges;
 - (4) Development and implementation of waste minimization plans to reduce the amount of pollutants discharged to the POTW;
 - (5) The unit charge or schedule of user charges and fees for the management of the wastewater discharged to the POTW;
 - (6) Requirements for installation and maintenance of inspection and sampling facilities and equipment, including flow measurement devices;
 - (7) A statement that compliance with the individual wastewater discharge permit does not relieve the permittee of responsibility for compliance with all applicable federal and state pretreatment standards, including those which become effective during the term of the individual wastewater discharge permit; and
 - (8) Other conditions as deemed appropriate by the city manager to ensure compliance with this division, and state and federal laws, rules, and regulations.

(Ord. No. 4110, § 2(5.2), 6-8-09)

Sec. 14-227. Permit issuance process, appeals.

The city manager shall provide public notice of the issuance of an individual wastewater discharge permit on the city website. Any person, including the user, may petition the city manager to reconsider the terms of an individual wastewater discharge permit within fifteen (15) days of notice of its issuance.

- (1) Failure to submit a timely petition for review shall be deemed to be a waiver of the administrative appeal.
- (2) In its petition, the appealing party must indicate the individual wastewater discharge permit provisions objected to, the reasons for this objection, and the alternative condition, if any, it seeks to place in the individual wastewater discharge permit.
- (3) The effectiveness of the individual wastewater discharge permit shall not be stayed pending the appeal.
- (4) If the city manager fails to act within fifteen (15) days, a request for reconsideration shall be deemed to be denied. Decisions not to reconsider an individual wastewater discharge permit,

- CODE OF ORDINANCES
Chapter 14 - WATER AND SEWERS
ARTICLE III. - SEWERS
DIVISION 5. - PRETREATMENT

Subdivision V. Individual Wastewater Discharge Permit Issuance

not to issue an individual wastewater discharge permit, or not to modify an individual wastewater discharge permit shall be considered final administrative actions for purposes of judicial review.

- (5) Aggrieved parties seeking judicial review of the final administrative individual wastewater discharge permit decision must do so by filing a complaint with the Circuit Court of Audrain County within thirty (30) days of the administrative decision.

(Ord. No. 4110, § 2(5.3), 6-8-09)

Sec. 14-228. Permit modification.

The city manager may modify an individual wastewater discharge permit for good cause, including, but not limited to, the following reasons:

- (1) To incorporate any new or revised federal, state, or local pretreatment standards or requirements;
- (2) To address significant alterations or additions to the user's operation, processes, or wastewater volume or character since the time of the individual wastewater discharge permit issuance;
- (3) A change in the POTW that requires either a temporary or permanent reduction or elimination of the authorized discharge;
- (4) Information indicating that the permitted discharge poses a threat to the city's POTW, city personnel, or the receiving waters;
- (5) Violation of any terms or conditions of the individual wastewater discharge permit;
- (6) Misrepresentations or failure to fully disclose all relevant facts in the wastewater discharge permit application or in any required reporting;
- (7) Revision of or a grant of variance from categorical pretreatment standards pursuant to Missouri 10 CSR 20-6.100;
- (8) To correct typographical or other errors in the individual wastewater discharge permit; or
- (9) To reflect a transfer of the facility ownership or operation to a new owner or operator where requested in accordance with [section 14-229](#)

(Ord. No. 4110, § 2(5.4), 6-8-09)

Sec. 14-229. Individual wastewater discharge permit transfer.

Individual wastewater discharge permits may be transferred to a new owner or operator only if the permittee gives at least thirty (30) days' advance notice to the city manager and the city manager approves the individual wastewater discharge permit transfer. The notice to the city manager must include a written certification by the new owner or operator which:

- (a) States that the new owner and/or operator has no immediate intent to change the facility's operations and processes;
- (b) Identifies the specific date on which the transfer is to occur; and
- (c) Acknowledges full responsibility for complying with the existing individual wastewater discharge permit.

- CODE OF ORDINANCES
Chapter 14 - WATER AND SEWERS
ARTICLE III. - SEWERS
DIVISION 5. - PRETREATMENT

Subdivision V. Individual Wastewater Discharge Permit Issuance

Failure to provide advance notice of a transfer renders the individual wastewater discharge permit void as of the date of facility transfer.

(Ord. No. 4110, § 2(5.5), 6-8-09)

Sec. 14-230. Individual wastewater discharge permit revocation.

The city manager may revoke an individual wastewater discharge permit for good cause, including, but not limited to, the following reasons:

- (a) Failure to notify the city manager of significant changes to the wastewater prior to the changed discharge;
- (b) Failure to provide prior notification to the city manager of changed conditions pursuant to [section 14-249](#)
- (c) Misrepresentation or failure to fully disclose all relevant facts in the wastewater discharge permit application;
- (d) Falsifying self-monitoring reports and certification statements;
- (e) Tampering with monitoring equipment;
- (f) Refusing to allow the city manager timely access to the facility premises and records;
- (g) Failure to meet effluent limitations;
- (h) Failure to pay fines;
- (i) Failure to pay sewer charges;
- (j) Failure to meet compliance schedules;
- (k) Failure to complete a wastewater survey or the wastewater discharge permit application;
- (l) Failure to provide advance notice of the transfer of business ownership of a permitted facility; or
- (m) Violation of any pretreatment standard or requirement, or any terms of the wastewater discharge permit or this ordinance.

Individual wastewater discharge permits shall be voidable upon cessation of operations or transfer of business ownership. All individual wastewater discharge permits issued to a user are void upon the issuance of a new individual wastewater discharge permit to that user.

(Ord. No. 4110, § 2(5.6), 6-8-09)

Sec. 14-231. Individual wastewater discharge permit reissuance.

A user with an expiring individual wastewater discharge permit shall apply for individual wastewater discharge permit reissuance by submitting a complete permit application, in accordance with [section 14-199](#), a minimum of ninety (90) days prior to the expiration of the user's existing individual wastewater discharge permit.

(Ord. No. 4110, § 2(5.7), 6-8-09)

Secs. 14-232—14-244. Reserved.

- CODE OF ORDINANCES
Chapter 14 - WATER AND SEWERS
ARTICLE III. - SEWERS
DIVISION 5. - PRETREATMENT

Subdivision VI. Reporting Requirements

Subdivision VI. Reporting Requirements

[Sec. 14-245. Baseline monitoring reports.](#)

[Sec. 14-246. Compliance schedule progress reports.](#)

[Sec. 14-247. Reports on compliance with categorical pretreatment standard deadline.](#)

[Sec. 14-248. Periodic compliance reports.](#)

[Sec. 14-249. Reports of changed conditions.](#)

[Sec. 14-250. Reports of potential problems.](#)

[Sec. 14-251. Reports from unpermitted users.](#)

[Sec. 14-252. Notice of violation/repeat sampling and reporting.](#)

[Sec. 14-253. Notification of the discharge of hazardous waste.](#)

[Sec. 14-254. Analytical requirements.](#)

[Sec. 14-255. Sample collection.](#)

[Sec. 14-256. Date of receipt of reports.](#)

[Sec. 14-257. Recordkeeping.](#)

[Sec. 14-258. Certification statements.](#)

[Secs. 14-259—14-274. Reserved.](#)

Sec. 14-245. Baseline monitoring reports.

- (a) Within either one hundred eighty (180) days after the effective date of a categorical pretreatment standard, or the final administrative decision on a category determination under Missouri 10 CSR 20-6.100, whichever is later, existing categorical industrial users currently discharging to or scheduled to discharge to the POTW shall submit to the city manager a report which contains the information listed in subsection (b), below. At least ninety (90) days prior to commencement of their discharge, new sources, and sources that become categorical industrial users subsequent to the promulgation of an applicable categorical standard, shall submit to the city manager a report which contains the information listed in subsection (b), below. A new source shall report the method of pretreatment it intends to use to meet applicable categorical standards. A new source also shall give estimates of its anticipated flow and quantity of pollutants to be discharged.
- (b) Users described above shall submit the information set forth below.
- (1) *[Required information.]* All information required in subsections [14-199\(a\)\(1\)a.](#), (2), (3)(a), and (6).
 - (2) *Measurement of pollutants.*
 - a. The user shall provide the information required in subsections [14-199\(a\)\(7\)a.](#) through d.
 - b. The user shall take a minimum of one (1) representative sample to compile that data necessary to comply with the requirements of this section.

- CODE OF ORDINANCES
Chapter 14 - WATER AND SEWERS
ARTICLE III. - SEWERS
DIVISION 5. - PRETREATMENT

Subdivision VI. Reporting Requirements

- c. Samples should be taken immediately downstream from pretreatment facilities if such exist or immediately downstream from the regulated process if no pretreatment exists. If other wastewaters are mixed with the regulated wastewater prior to pretreatment the user should measure the flows and concentrations necessary to allow use of the combined wastestream formula to evaluate compliance with the pretreatment standards. Where an alternate concentration or mass limit has been calculated in accordance with Missouri 10 CSR 20-6.100 this adjusted limit along with supporting data shall be submitted to the city.
 - d. Sampling and analysis shall be performed in accordance with [section 14-254](#)
 - e. The city manager may allow the submission of a baseline report which utilizes only historical data so long as the data provides information sufficient to determine the need for industrial pretreatment measures.
 - f. The baseline report shall indicate the time, date and place of sampling and methods of analysis, and shall certify that such sampling and analysis is representative of normal work cycles and expected pollutant discharges to the POTW.
- (3) *Compliance certification.* A statement, reviewed by the user's authorized representative as defined in [section 14-143](#) and certified by a qualified professional, indicating whether pretreatment standards are being met on a consistent basis, and, if not, whether additional operation and maintenance (O&M) and/or additional pretreatment is required to meet the pretreatment standards and requirements.
- (4) *Compliance schedule.* If additional pretreatment and/or O&M will be required to meet the pretreatment standards, the shortest schedule by which the user will provide such additional pretreatment and/or O&M must be provided. The completion date in this schedule shall not be later than the compliance date established for the applicable pretreatment standard. A compliance schedule pursuant to this section must meet the requirements set out in [section 14-246](#)
- (5) *Signature and report certification.* All baseline monitoring reports must be certified in accordance with [section 14-258](#) and signed by an authorized representative as defined in [section 14-143](#)

(Ord. No. 4110, § 2(6.1), 6-8-09)

Sec. 14-246. Compliance schedule progress reports.

The following conditions shall apply to the compliance schedule required by subsection [14-245\(b\)\(4\)](#):

- (a) The schedule shall contain progress increments in the form of dates for the commencement and completion of major events leading to the construction and operation of additional pretreatment required for the user to meet the applicable pretreatment standards (such events include, but are not limited to, hiring an engineer, completing preliminary and final plans, executing contracts for major components, commencing and completing construction, and beginning and conducting routine operation);
- (b) No increment referred to above shall exceed nine (9) months;
- (c) The user shall submit a progress report to the city manager no later than fourteen (14) days following each date in the schedule and the final date of compliance including, as a minimum, whether or not it complied with the increment of progress, the reason for any delay, and, if appropriate, the steps being taken by the user to return to the established schedule; and

- CODE OF ORDINANCES
Chapter 14 - WATER AND SEWERS
ARTICLE III. - SEWERS
DIVISION 5. - PRETREATMENT

Subdivision VI. Reporting Requirements

- (d) In no event shall more than nine (9) months elapse between such progress reports to the city manager.

(Ord. No. 4110, § 2(6.2), 6-8-09)

Sec. 14-247. Reports on compliance with categorical pretreatment standard deadline.

Within ninety (90) days following the date for final compliance with applicable categorical pretreatment standards, or in the case of a new source following commencement of the introduction of wastewater into the POTW, any user subject to such pretreatment standards and requirements shall submit to the city manager a report containing the information described in subsections [14-199\(a\)\(6\)](#) and [\(7\)](#) and [14-245\(b\)\(2\)](#). For users subject to equivalent mass or concentration limits established in accordance with the procedures in [section 14-156](#), this report shall contain a reasonable measure of the user's longterm production rate. For all other users subject to categorical pretreatment standards expressed in terms of allowable pollutant discharge per unit of production (or other measure of operation), this report shall include the user's actual production during the appropriate sampling period. All compliance reports must be signed and certified in accordance with [section 14-258](#). All sampling will be done in conformance with [section 14-255](#).

(Ord. No. 4110, § 2(6.3), 6-8-09)

Sec. 14-248. Periodic compliance reports.

- (a) All significant industrial users must, at a frequency determined by the city manager, submit monthly reports indicating the nature, concentration of pollutants in the discharge which are limited by pretreatment standards and the measured or estimated average and maximum daily flows for the reporting period. In cases where the pretreatment standard requires compliance with a best management practice (BMP) or pollution prevention alternative, the user must submit documentation required by the city manager or the pretreatment standard necessary to determine the compliance status of the user.
- (b) All periodic compliance reports must be signed and certified in accordance with [section 14-258](#)
- (c) All wastewater samples must be representative of the user's discharge. Wastewater monitoring and flow measurement facilities shall be properly operated, kept clean, and maintained in good working order at all times. The failure of a user to keep its monitoring facility in good working order shall not be grounds for the user to claim that sample results are unrepresentative of its discharge.
- (d) If a user subject to the reporting requirement in this section monitors any regulated pollutant at the appropriate sampling location more frequently than required by the city manager, using the procedures prescribed in [section 14-255](#), the results of this monitoring shall be included in the report.
- (e) Electronic reports intended to satisfy the requirements of this section may be submitted to the pretreatment coordinator and the wastewater superintendent by email or other electronic means. They must be in jpeg or rich text file (rtf) formats.

(Ord. No. 4110(6.4), § 2, 6-8-09)

- CODE OF ORDINANCES
Chapter 14 - WATER AND SEWERS
ARTICLE III. - SEWERS
DIVISION 5. - PRETREATMENT

Subdivision VI. Reporting Requirements

Sec. 14-249. Reports of changed conditions.

Each user must notify the city manager of any significant changes to the user's operations or system which might alter the nature, quality, or volume of its wastewater at least five (5) days before the change.

- (a) The city manager may require the user to submit such information as may be deemed necessary to evaluate the changed condition, including the submission of a wastewater discharge permit application under [section 14-199](#)
- (b) The city manager may issue an individual wastewater discharge permit under [section 14-231](#) or modify an existing wastewater discharge permit under [section 14-228](#) in response to changed conditions or anticipated changed conditions.

(Ord. No. 4110, § 2(6.5), 6-8-09)

Sec. 14-250. Reports of potential problems.

- (a) In the case of any discharge, including, but not limited to, accidental discharges, discharges of a nonroutine, episodic nature, a noncustomary batch discharge, a slug discharge or slug load, that might cause potential problems for the POTW, the user shall immediately telephone and notify the city manager of the incident. This notification shall include the location of the discharge, type of waste, concentration and volume, if known, and corrective actions taken by the user.
- (b) Within five (5) days following such discharge, the user shall, unless waived by the city manager, submit a detailed written report describing the cause(s) of the discharge and the measures to be taken by the user to prevent similar future occurrences. Such notification shall not relieve the user of any expense, loss, damage, or other liability which might be incurred as a result of damage to the POTW, natural resources, or any other damage to person or property; nor shall such notification relieve the user of any fines, penalties, or other liability which may be imposed pursuant to this division.
- (c) A notice shall be permanently posted on the user's bulletin board or other prominent place advising employees who to call in the event of a discharge described in subsection (a), above. Employers shall ensure that all employees, who could cause such a discharge to occur, are advised of the emergency notification procedure.
- (d) Significant industrial users are required to notify the city manager immediately of any changes at its facility affecting the potential for a slug discharge.

(Ord. No. 4110, § 2(6.6), 6-8-09)

Sec. 14-251. Reports from unpermitted users.

All users not required to obtain an individual wastewater discharge permit shall provide appropriate reports to the city manager as the city manager may require.

(Ord. No. 4110, § 2(6.7), 6-8-09)

- CODE OF ORDINANCES
Chapter 14 - WATER AND SEWERS
ARTICLE III. - SEWERS
DIVISION 5. - PRETREATMENT

Subdivision VI. Reporting Requirements

Sec. 14-252. Notice of violation/repeat sampling and reporting.

If sampling performed by a user indicates a violation, the user must notify the city manager within twenty-four (24) hours of becoming aware of the violation. The user shall also repeat the sampling and analysis and submit the results of the repeat analysis to the city manager within thirty (30) days after becoming aware of the violation. Resampling by the industrial user is not required if the city performs sampling at the user's facility at least once a month, or if the city performs sampling at the user between the time when the initial sampling was conducted and the time when the user or the city receives the results of this sampling, or if the city has performed the sampling and analysis in lieu of the industrial user.

(Ord. No. 4110, § 2(6.8), 6-8-09)

Sec. 14-253. Notification of the discharge of hazardous waste.

- (a) Any user who commences the discharge of hazardous waste shall notify the POTW, the EPA regional waste management division director, and state hazardous waste authorities, in writing, of any discharge into the POTW of a substance which, if otherwise disposed of, would be a hazardous waste under 40 CFR part 261. Such notification must include the name of the hazardous waste as set forth in 40 CFR part 261, the EPA hazardous waste number, and the type of discharge (continuous, batch, or other). If the user discharges more than one hundred (100) kilograms of such waste per calendar month to the POTW, the notification also shall contain the following information to the extent such information is known and readily available to the user: an identification of the hazardous constituents contained in the wastes, an estimation of the mass and concentration of such constituents in the wastestream discharged during that calendar month, and an estimation of the mass of constituents in the wastestream expected to be discharged during the following twelve (12) months. All notifications must take place no later than one hundred eighty (180) days after the discharge commences. Any notification under this section need be submitted only once for each hazardous waste discharged. However, notifications of changed conditions must be submitted under [section 14-249](#). The notification requirement in this section does not apply to pollutants already reported by users subject to categorical pretreatment standards under the self-monitoring requirements of sections [14-245](#), [14-247](#) and [14-248](#)
- (b) Dischargers are exempt from the requirements of subsection (a), above, during a calendar month in which they discharge no more than fifteen (15) kilograms of hazardous wastes, unless the wastes are acute hazardous wastes as specified in 40 CFR 261.30(d) and 261.33(e). Discharge of more than fifteen (15) kilograms of nonacute hazardous wastes in a calendar month, or of any quantity of acute hazardous wastes as specified in 40 CFR 261.30(d) and 261.33(e), requires a one-time notification. Subsequent months during which the user discharges more than such quantities of any hazardous waste do not require additional notification.
- (c) In the case of any new regulations under section 3001 of RCRA identifying additional characteristics of hazardous waste or listing any additional substance as a hazardous waste, the user must notify the city manager, the EPA regional waste management waste division director, and state hazardous waste authorities of the discharge of such substance within ninety (90) days of the effective date of such regulations.
- (d) In the case of any notification made under this section, the user shall certify that it has a program in place to reduce the volume and toxicity of hazardous wastes generated to the degree it has determined to be economically practical.

- CODE OF ORDINANCES
Chapter 14 - WATER AND SEWERS
ARTICLE III. - SEWERS
DIVISION 5. - PRETREATMENT

Subdivision VI. Reporting Requirements

- (e) This provision does not create a right to discharge any substance not otherwise permitted to be discharged by this division, a permit issued thereunder, or any applicable federal or state law.

(Ord. No. 4110, § 2(6.9), 6-8-09)

Sec. 14-254. Analytical requirements.

All pollutant analyses, including sampling techniques, to be submitted as part of a wastewater discharge permit application or report shall be performed in accordance with the techniques prescribed in 40 CFR part 136 and amendments thereto, unless otherwise specified in an applicable categorical pretreatment standard. If 40 CFR part 136 does not contain sampling or analytical techniques for the pollutant in question, or where the EPA determines that the part 136 sampling and analytical techniques are inappropriate for the pollutant in question, sampling and analyses shall be performed by using validated analytical methods or any other applicable sampling and analytical procedures, including procedures suggested by the city manager or other parties approved by the EPA.

(Ord. No. 4110, § 2(6.10), 6-8-09)

Sec. 14-255. Sample collection.

Samples collected to satisfy reporting requirements must be based on data obtained through appropriate sampling and analysis performed during the period covered by the report, based on data that is representative of conditions occurring during the reporting period.

- (a) Except as indicated in subsections (b) and (c) below, the user must collect wastewater samples using twenty-four-hour flow-proportional composite sampling techniques, unless time-proportional composite sampling or grab sampling is authorized by the city manager. Where time-proportional composite sampling or grab sampling is authorized by the city, the samples must be representative of the discharge. Using protocols (including appropriate preservation) specified in 40 CFR part 136 and appropriate EPA guidance, multiple grab samples collected during a twenty-four-hour period may be composited prior to the analysis as follows: for cyanide, total phenols, and sulfides the samples may be composited in the laboratory or in the field; for volatile organics and oil and grease, the samples may be composited in the laboratory. Composite samples for other parameters unaffected by the compositing procedures as documented in approved EPA methodologies may be authorized by the city, as appropriate. In addition, grab samples may be required to show compliance with instantaneous limits.
- (b) Samples for oil and grease, temperature, pH, cyanide, total phenols, sulfides, and volatile organic compounds must be obtained using grab collection techniques.
- (c) For sampling required in support of baseline monitoring and ninety-day compliance reports required in sections [14-245](#) and [14-247](#), a minimum of four (4) grab samples must be used for pH, cyanide, total phenols, oil and grease, sulfide and volatile organic compounds for facilities for which historical sampling data do not exist; for facilities for which historical sampling data are available, the city manager may authorize a lower minimum. For the reports required by [section 14-248](#), the industrial user is required to collect the number of grab samples necessary to assess and assure compliance with applicable pretreatment standards and requirements.

(Ord. No. 4110, § 2(6.11), 6-8-09)

- CODE OF ORDINANCES
Chapter 14 - WATER AND SEWERS
ARTICLE III. - SEWERS
DIVISION 5. - PRETREATMENT

Subdivision VI. Reporting Requirements

Sec. 14-256. Date of receipt of reports.

Written reports will be deemed to have been submitted on the date postmarked. For reports, which are not mailed, postage prepaid, into a mail facility serviced by the United States Postal Service, the date of receipt of the report shall govern.

(Ord. No. 4110, § 2(6.12), 6-8-09)

Sec. 14-257. Recordkeeping.

Users subject to the reporting requirements of this division shall retain, and make available for inspection and copying, all records of information obtained pursuant to any monitoring activities required by this division, any additional records of information obtained pursuant to monitoring activities undertaken by the user independent of such requirements, and documentation associated with best management practices established under subsection [14-258](#). Records shall include the date, exact place, method, and time of sampling, and the name of the person(s) taking the samples; the dates analyses were performed; who performed the analyses; the analytical techniques or methods used; and the results of such analyses. These records shall remain available for a period of at least three (3) years. This period shall be automatically extended for the duration of any litigation concerning the user or the city, or where the user has been specifically notified of a longer retention period by the city manager.

(Ord. No. 4110, § 2(6.13), 6-8-09)

Sec. 14-258. Certification statements.

Certification of permit applications, user reports and initial monitoring waiver. The following certification statement is required to be signed and submitted by: users submitting permit applications in accordance with subdivision IV; users submitting baseline monitoring reports under subsection [14-245\(b\)\(2\)c.](#); users submitting reports on compliance with the categorical pretreatment standard deadlines under [section 14-247](#); users submitting periodic compliance reports required by subsections [14-248\(a\)](#) through (c); and users submitting an initial request to forego sampling of a pollutant on the basis of subsection [14-245\(b\)\(4\)](#). The following certification statement must be signed by an authorized representative as defined in [section 14-143](#):

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

(Ord. No. 4110, § 2(6.14), 6-8-09)

Secs. 14-259—14-274. Reserved.

- CODE OF ORDINANCES
Chapter 14 - WATER AND SEWERS
ARTICLE III. - SEWERS
DIVISION 5. - PRETREATMENT

Subdivision VII. Compliance Monitoring

Subdivision VII. Compliance Monitoring

[Sec. 14-275. Right of entry; inspection and sampling.](#)

[Sec. 14-276. Search warrants.](#)

[Secs. 14-277—14-289. Reserved.](#)

Sec. 14-275. Right of entry; inspection and sampling.

The city manager shall have the right to enter the premises of any user to determine whether the user is complying with all requirements of this division and any individual wastewater discharge permit or order issued hereunder. Users shall allow the city manager ready access to all parts of the premises for the purposes of inspection, sampling, records examination and copying, and the performance of any additional duties.

- (a) Where a user has security measures in force which require proper identification and clearance before entry into its premises, the user shall make necessary arrangements with its security guards so that, upon presentation of suitable identification, the city manager shall be permitted to enter without delay for the purposes of performing specific responsibilities.
- (b) The city manager shall have the right to set up on the user's property, or require installation of, such devices as are necessary to conduct sampling and/or metering of the user's operations.
- (c) The city manager may require the user to install monitoring equipment as necessary. The facility's sampling and monitoring equipment shall be maintained at all times in a safe and proper operating condition by the user at its own expense. All devices used to measure wastewater flow and quality shall be calibrated to ensure their accuracy in accordance with the manufacturer's recommended schedule, but in any case not less than annually.
- (d) Any temporary or permanent obstruction to safe and easy access to the facility to be inspected and/or sampled shall be promptly removed by the user at the written or verbal request of the city manager and shall not be replaced. The costs of clearing such access shall be borne by the user.
- (e) Unreasonable delays in allowing the city manager access to the user's premises shall be a violation of this division.

(Ord. No. 4110, § 2(7.1), 6-8-09)

Sec. 14-276. Search warrants.

If the city manager has been refused access to a building, structure, or property, or any part thereof, and is able to demonstrate probable cause to believe that there may be a violation of this division, or that there is a need to inspect and/or sample as part of a routine inspection and sampling program of the city designed to verify compliance with this division or any permit or order issued hereunder, or to protect the overall public health, safety and welfare of the community, the city manager may seek issuance of a search warrant from the Circuit Court of Audrain County.

(Ord. No. 4110, § 2(7.2), 6-8-09)

- CODE OF ORDINANCES
Chapter 14 - WATER AND SEWERS
ARTICLE III. - SEWERS
DIVISION 5. - PRETREATMENT

Subdivision VII. Compliance Monitoring

Secs. 14-277—14-289. Reserved.

- CODE OF ORDINANCES
Chapter 14 - WATER AND SEWERS
ARTICLE III. - SEWERS
DIVISION 5. - PRETREATMENT

Subdivision VIII. Confidential Information

Subdivision VIII. Confidential Information

[Sec. 14-290. Confidential information.](#)

Sec. 14-290. Confidential information.

Information and data on a user obtained from reports, surveys, wastewater discharge permit applications, individual wastewater discharge permits, and monitoring programs, and from the city's inspection and sampling activities, shall be available to the public without restriction, unless the user specifically requests, and is able to demonstrate to the satisfaction of the city manager, that the release of such information would divulge information, processes, or methods of production entitled to protection as trade secrets under applicable state law. Any such request must be asserted at the time of submission of the information or data. When requested and demonstrated by the user furnishing a report that such information should be held confidential, the portions of a report which might disclose trade secrets or secret processes shall not be made available for inspection by the public, but shall be made available immediately upon request to governmental agencies for uses related to the NPDES program or pretreatment program, and in enforcement proceedings involving the person furnishing the report. Wastewater constituents and characteristics and other effluent data, as defined at 40 CFR 2.302 shall not be recognized as confidential information and shall be available to the public without restriction.

(Ord. No. 4110, § 2(8), 6-8-09)

- CODE OF ORDINANCES
Chapter 14 - WATER AND SEWERS
ARTICLE III. - SEWERS
DIVISION 5. - PRETREATMENT

Subdivision IX. Publication of Users in Significant Noncompliance

Subdivision IX. Publication of Users in Significant Noncompliance

[Sec. 14-291. Publication of users in significant noncompliance.](#)

[Secs. 14-292—14-299. Reserved.](#)

Sec. 14-291. Publication of users in significant noncompliance.

The city manager shall publish annually, in a newspaper of general circulation that provides meaningful public notice within the jurisdictions served by the POTW, a list of the users which, at any time during the previous twelve (12) months, were in significant noncompliance with applicable pretreatment standards and requirements. The term "significant noncompliance" shall be applicable to all significant industrial users (or any other industrial user that violates subsections (c), (d) or (h)) and shall mean:

- (a) Chronic violations of wastewater discharge limits, defined here as those in which sixty-six (66) percent or more of all the measurements taken for the same pollutant parameter taken during a six-month period exceed (by any magnitude) a numeric pretreatment standard or requirement, including instantaneous limits as defined in subdivision II;
- (b) Technical review criteria (TRC) violations, defined here as those in which thirty-three (33) percent or more of wastewater measurements taken for each pollutant parameter during a six-month period equals or exceeds the product of the numeric pretreatment standard or requirement including instantaneous limits, as defined by subdivision II multiplied by the applicable criteria (1.4 for BOD, TSS, fats, oils and grease, and 1.2 for all other pollutants except pH);
- (c) Any other violation of a pretreatment standard or requirement as defined by subdivision II (daily maximum) that the city manager determines has caused, alone or in combination with other discharges, interference or pass through, including endangering the health of POTW personnel or the general public;
- (d) Any discharge of a pollutant that has caused imminent endangerment to the public or to the environment, or has resulted in the city's exercise of its emergency authority to halt or prevent such a discharge;
- (e) Failure to meet, within ninety (90) days of the scheduled date, a compliance schedule milestone contained in an individual wastewater discharge permit or enforcement order for starting construction, completing construction, or attaining final compliance;
- (f) Failure to provide within forty-five (45) days after the due date, any required reports, including baseline monitoring reports, reports on compliance with categorical pretreatment standard deadlines, periodic self-monitoring reports, and reports on compliance with compliance schedules;
- (g) Failure to accurately report noncompliance; or
- (h) Any other violation(s), which may include a violation of best management practices, which the city manager determines will adversely affect the operation or implementation of the local pretreatment program.

(Ord. No. 4110, § 2(9), 6-8-09)

- CODE OF ORDINANCES
Chapter 14 - WATER AND SEWERS
ARTICLE III. - SEWERS
DIVISION 5. - PRETREATMENT

Subdivision IX. Publication of Users in Significant Noncompliance

Secs. 14-292—14-299. Reserved.

- CODE OF ORDINANCES
Chapter 14 - WATER AND SEWERS
ARTICLE III. - SEWERS
DIVISION 5. - PRETREATMENT

Subdivision X. Administrative Enforcement Remedies

Subdivision X. Administrative Enforcement Remedies

[Sec. 14-300. Notification of violation.](#)

[Sec. 14-301. Consent orders.](#)

[Sec. 14-302. Show cause hearing.](#)

[Sec. 14-303. Compliance orders.](#)

[Sec. 14-304. Cease and desist orders.](#)

[Sec. 14-305. Administrative fines.](#)

[Sec. 14-306. Emergency suspensions.](#)

[Sec. 14-307. Termination of discharge.](#)

[Secs. 14-308—14-324. Reserved.](#)

Sec. 14-300. Notification of violation.

When the city manager finds that a user has violated, or continues to violate, any provision of this division, an individual wastewater discharge permit, or order issued hereunder, or any other pretreatment standard or requirement, the city manager may serve upon that user a written notice of violation. Within five (5) days of the receipt of such notice, an explanation of the violation and a plan for the satisfactory correction and prevention thereof, to include specific required actions, shall be submitted by the user to the city manager. Submission of such a plan in no way relieves the user of liability for any violations occurring before or after receipt of the notice of violation. Nothing in this section shall limit the authority of the city manager to take any action, including emergency actions or any other enforcement action, without first issuing a notice of violation.

(Ord. No. 4110, § 2(10.1), 6-8-09)

Sec. 14-301. Consent orders.

The city manager may enter into consent orders, assurances of compliance, or other similar documents establishing an agreement with any user responsible for noncompliance. Such documents shall include specific action to be taken by the user to correct the noncompliance within a time period specified by the document. Such documents shall have the same force and effect as the administrative orders issued pursuant to sections [14-303](#) and [14-304](#) and shall be judicially enforceable.

(Ord. No. 4110, § 2(10.2), 6-8-09)

Sec. 14-302. Show cause hearing.

The city manager may order a user which has violated, or continues to violate, any provision of this division, an individual wastewater discharge permit, or order issued hereunder, or any other pretreatment standard or requirement, to appear before the city manager and show cause why the proposed enforcement action should not be taken. Notice shall be served on the user specifying the time and place

- CODE OF ORDINANCES
Chapter 14 - WATER AND SEWERS
ARTICLE III. - SEWERS
DIVISION 5. - PRETREATMENT

Subdivision X. Administrative Enforcement Remedies

for the meeting, the proposed enforcement action, the reasons for such action, and a request that the user show cause why the proposed enforcement action should not be taken. The notice of the meeting shall be served personally or by registered or certified mail (return receipt requested) at least seven (7) days prior to the hearing. Such notice may be served on any authorized representative of the user as defined in [section 14-143](#) and required by subsection [14-199\(a\)](#). A show cause hearing shall not be a bar against, or prerequisite for, taking any other action against the user.

(Ord. No. 4110, § 2(10.3), 6-8-09)

Sec. 14-303. Compliance orders.

When the city manager finds that a user has violated, or continues to violate, any provision of this division, an individual wastewater discharge permit, or order issued hereunder, or any other pretreatment standard or requirement, the city manager may issue an order to the user responsible for the discharge directing that the user come into compliance within a specified time. If the user does not come into compliance within the time provided, sewer service may be discontinued unless adequate treatment facilities, devices, or other related appurtenances are installed and properly operated. Compliance orders also may contain other requirements to address the noncompliance, including additional self-monitoring and management practices designed to minimize the amount of pollutants discharged to the sewer. A compliance order may not extend the deadline for compliance established for a pretreatment standard or requirement, nor does a compliance order relieve the user of liability for any violation, including any continuing violation. Issuance of a compliance order shall not be a bar against, or a prerequisite for, taking any other action against the user.

(Ord. No. 4110, § 2(10.4), 6-8-09)

Sec. 14-304. Cease and desist orders.

When the city manager finds that a user has violated, or continues to violate, any provision of this division, an individual wastewater discharge permit, or order issued hereunder, or any other pretreatment standard or requirement, or that the user's past violations are likely to recur, the city manager may issue an order to the user directing it to cease and desist all such violations and directing the user to:

- (a) Immediately comply with all requirements; and
- (b) Take such appropriate remedial or preventive action as may be needed to properly address a continuing or threatened violation, including halting operations and/or terminating the discharge. Issuance of a cease and desist order shall not be a bar against, or a prerequisite for, taking any other action against the user.

(Ord. No. 4110, § 2(10.5), 6-8-09)

Sec. 14-305. Administrative fines.

- (a) When the city manager finds that a user has violated, or continues to violate, any provision of this division, an individual wastewater discharge permit, or order issued hereunder, or any other pretreatment standard or requirement, the city manager may fine such user in an amount not to exceed five thousand dollars (\$5,000.00) per violation per day. Such fines shall be assessed on a per-violation, per-day basis. In the case of monthly or other longterm average discharge limits, fines shall be assessed for each day during the period of violation.

- CODE OF ORDINANCES
Chapter 14 - WATER AND SEWERS
ARTICLE III. - SEWERS
DIVISION 5. - PRETREATMENT

Subdivision X. Administrative Enforcement Remedies

- (b) Unpaid charges, fines, and penalties shall, after thirty (30) calendar days, be assessed an additional penalty of nine (9) percent of the unpaid balance, and interest shall accrue thereafter at a rate of nine (9) percent per month. A lien against the user's property shall be sought for unpaid charges, fines, and penalties.
- (c) Users desiring to dispute such fines must file a written request for the city manager to reconsider the fine along with full payment of the fine amount within seven (7) days of being notified of the fine. Where a request has merit, the city manager may convene a hearing on the matter. In the event the user's appeal is successful, the payment, together with any interest accruing thereto, shall be returned to the user. The city manager may add the costs of preparing administrative enforcement actions, such as notices and orders, to the fine.
- (d) Issuance of an administrative fine shall not be a bar against, or a prerequisite for, taking any other action against the user.

(Ord. No. 4110, § 2(10.6), 6-8-09)

Sec. 14-306. Emergency suspensions.

The city manager may immediately suspend a user's discharge, after informal notice to the user, whenever such suspension is necessary to stop an actual or threatened discharge, which reasonably appears to present, or cause an imminent or substantial endangerment to the health or welfare of persons. The city manager may also immediately suspend a user's discharge, after notice and opportunity to respond, that threatens to interfere with the operation of the POTW, or which presents, or may present, an endangerment to the environment.

- (a) Any user notified of a suspension of its discharge shall immediately stop or eliminate its contribution. In the event of a user's failure to immediately comply voluntarily with the suspension order, the city manager may take such steps as deemed necessary, including immediate severance of the sewer connection, to prevent or minimize damage to the POTW, its receiving stream, or endangerment to any individuals. The city manager may allow the user to recommence its discharge when the user has demonstrated to the satisfaction of the city manager that the period of endangerment has passed, unless the termination proceedings in [section 14-307](#) are initiated against the user.
- (b) A user that is responsible, in whole or in part, for any discharge presenting imminent endangerment shall submit a detailed written statement, describing the causes of the harmful contribution and the measures taken to prevent any future occurrence, to the city manager prior to the date of any show cause or termination hearing under sections [14-302](#) or [14-307](#)

Nothing in this section shall be interpreted as requiring a hearing prior to any emergency suspension under this section.

(Ord. No. 4110, § 2(10.7), 6-8-09)

Sec. 14-307. Termination of discharge.

In addition to the provisions in [section 14-230](#), any user who violates the following conditions is subject to discharge termination:

- (a) Violation of individual wastewater discharge permit conditions;
- (b) Failure to accurately report the wastewater constituents and characteristics of its discharge;

- CODE OF ORDINANCES
Chapter 14 - WATER AND SEWERS
ARTICLE III. - SEWERS
DIVISION 5. - PRETREATMENT

Subdivision X. Administrative Enforcement Remedies

- (c) Failure to report significant changes in operations or wastewater volume, constituents, and characteristics prior to discharge;
- (d) Refusal of reasonable access to the user's premises for the purpose of inspection, monitoring, or sampling; or
- (e) Violation of the pretreatment standards in subdivision II.

Such user will be notified of the proposed termination of its discharge and be offered an opportunity to show cause under [section 14-302](#) why the proposed action should not be taken. Exercise of this option by the city manager shall not be a bar to, or a prerequisite for, taking any other action against the user.

(Ord. No. 4110, § 2(10.8), 6-8-09)

Secs. 14-308—14-324. Reserved.

- CODE OF ORDINANCES
Chapter 14 - WATER AND SEWERS
ARTICLE III. - SEWERS
DIVISION 5. - PRETREATMENT

Subdivision XI. Judicial Enforcement Remedies

Subdivision XI. Judicial Enforcement Remedies

[Sec. 14-325. Injunctive relief.](#)

[Sec. 14-326. Civil penalties.](#)

[Sec. 14-327. Remedies non-exclusive.](#)

[Secs. 14-328—14-339. Reserved.](#)

Sec. 14-325. Injunctive relief.

When the city manager finds that a user has violated, or continues to violate, any provision of this division, an individual wastewater discharge permit, or order issued hereunder, or any other pretreatment standard or requirement, the city manager may petition the Circuit Court of Audrain county through the city's attorney for the issuance of a temporary or permanent injunction, as appropriate, which restrains or compels the specific performance of the individual wastewater discharge permit, order, or other requirement imposed by this division on activities of the user. The city manager may also seek such other action as is appropriate for legal and/or equitable relief, including a requirement for the user to conduct environmental remediation. A petition for injunctive relief shall not be a bar against, or a prerequisite for, taking any other action against a user.

(Ord. No. 4110, § 2(11.1), 6-8-09)

Sec. 14-326. Civil penalties.

- (a) A user who has violated, or continues to violate, any provision of this division, an individual wastewater discharge permit, or order issued hereunder, or any other pretreatment standard or requirement shall be liable to the city for a maximum civil penalty of five thousand dollars (\$5,000.00) per violation, per day. In the case of a monthly or other longterm average discharge limit, penalties shall accrue for each day during the period of the violation.
- (b) The city manager may recover reasonable attorneys' fees, court costs, and other expenses associated with enforcement activities, including sampling and monitoring expenses, and the cost of any actual damages incurred by the city.
- (c) In determining the amount of civil liability, the court shall take into account all relevant circumstances, including, but not limited to, the extent of harm caused by the violation, the magnitude and duration of the violation, any economic benefit gained through the user's violation, corrective actions by the user, the compliance history of the user, and any other factor as justice requires.
- (d) Filing a suit for civil penalties shall not be a bar against, or a prerequisite for, taking any other action against a user.

(Ord. No. 4110, § 2(11.2), 6-8-09)

- CODE OF ORDINANCES
Chapter 14 - WATER AND SEWERS
ARTICLE III. - SEWERS
DIVISION 5. - PRETREATMENT

Subdivision XI. Judicial Enforcement Remedies

Sec. 14-327. Remedies non-exclusive.

The remedies provided for in this division are not exclusive. The city manager may take any, all, or any combination of these actions against a noncompliant user. Enforcement of pretreatment violations will generally be in accordance with the city's enforcement response plan. However, the city manager may take other action against any user when the circumstances warrant. Further, the city manager is empowered to take more than one (1) enforcement action against any noncompliant user.

(Ord. No. 4110, § 2(11.3), 6-8-09)

Secs. 14-328—14-339. Reserved.

- CODE OF ORDINANCES
Chapter 14 - WATER AND SEWERS
ARTICLE III. - SEWERS
DIVISION 5. - PRETREATMENT

Subdivision XII. Supplemental Enforcement Action

Subdivision XII. Supplemental Enforcement Action

[Sec. 14-340. Penalties for late reports.](#)

[Sec. 14-341. Liability insurance.](#)

[Sec. 14-342. Payment of outstanding fees and penalties.](#)

[Sec. 14-343. Water supply severance.](#)

[Sec. 14-344. Public nuisances.](#)

[Secs. 14-345—14-359. Reserved.](#)

Sec. 14-340. Penalties for late reports.

A penalty of three hundred dollars (\$300.00) shall be assessed to any user for each day that a report required by this division, a permit or order issued hereunder is late, beginning five (5) days after the date the report is due. Actions taken by the city manager to collect late reporting penalties shall not limit the city manager's authority to initiate other enforcement actions that may include penalties for late reporting violations.

(Ord. No. 4110, § 2(12.1), 6-8-09)

Sec. 14-341. Liability insurance.

The city manager may decline to issue or reissue an individual wastewater discharge [permit] to any user who has failed to comply with any provision of this division, a previous individual wastewater discharge permit, or order issued hereunder, or any other pretreatment standard or requirement, unless the user first submits proof that it has obtained financial assurances sufficient to restore or repair damage to the POTW caused by its discharge.

(Ord. No. 4110, § 2(12.2), 6-8-09)

Sec. 14-342. Payment of outstanding fees and penalties.

The city manager may decline to issue or reissue an individual wastewater discharge permit to any user who has failed to pay any outstanding fees, fines or penalties incurred as a result of any provision of this division, a previous individual wastewater discharge permit, or order issued hereunder.

(Ord. No. 4110, § 2(12.3), 6-8-09)

Sec. 14-343. Water supply severance.

Whenever a user has violated or continues to violate any provision of this division, an individual wastewater discharge permit, or order issued hereunder, or any other pretreatment standard or requirement, water service to the user may be severed. Service will recommence, at the user's expense, only after the user has satisfactorily demonstrated its ability to comply.

- CODE OF ORDINANCES
Chapter 14 - WATER AND SEWERS
ARTICLE III. - SEWERS
DIVISION 5. - PRETREATMENT

Subdivision XII. Supplemental Enforcement Action

(Ord. No. 4110, § 2(12.4), 6-8-09)

Sec. 14-344. Public nuisances.

A violation of any provision of this division, an individual wastewater discharge permit, or order issued hereunder, or any other pretreatment standard or requirement is hereby declared a public nuisance and shall be corrected or abated as directed by the city manager. Any person(s) creating a public nuisance shall be subject to the provisions of [chapter 10](#), article V of the City Code governing such nuisances, including reimbursing the city for any costs incurred in removing, abating, or remedying said nuisance.

(Ord. No. 4110, § 2(12.5), 6-8-09)

Secs. 14-345—14-359. Reserved.

- CODE OF ORDINANCES
Chapter 14 - WATER AND SEWERS
ARTICLE III. - SEWERS
DIVISION 5. - PRETREATMENT

Subdivision XIII. Affirmative Defenses to Discharge Violations

Subdivision XIII. Affirmative Defenses to Discharge Violations

[Sec. 14-360. Upset.](#)

[Sec. 14-361. Prohibited discharge standards.](#)

[Sec. 14-362. Bypass.](#)

[Secs. 14-363—14-374. Reserved.](#)

Sec. 14-360. Upset.

- (a) For the purposes of this section, upset means an exceptional incident in which there is unintentional and temporary noncompliance with categorical pretreatment standards because of factors beyond the reasonable control of the user. An upset does not include noncompliance to the extent caused by operational error, improperly designed treatment facilities, inadequate treatment facilities, lack of preventive maintenance, or careless or improper operation.
- (b) An upset shall constitute an affirmative defense to an action brought for noncompliance with categorical pretreatment standards if the requirements of subsection (c), below, are met.
- (c) A user who wishes to establish the affirmative defense of upset shall demonstrate, through properly signed, contemporaneous operating logs, or other relevant evidence that:
 - (1) An upset occurred and the user can identify the cause(s) of the upset;
 - (2) The facility was at the time being operated in a prudent and workman-like manner and in compliance with applicable operation and maintenance procedures; and
 - (3) The user has submitted the following information to the city manager within twenty-four (24) hours of becoming aware of the upset (if this information is provided orally, a written submission must be provided within five (5) days):
 - a. A description of the indirect discharge and cause of noncompliance;
 - b. The period of noncompliance, including exact dates and times or, if not corrected, the anticipated time the noncompliance is expected to continue; and
 - c. Steps being taken and/or planned to reduce, eliminate, and prevent recurrence of the noncompliance.
- (d) In any enforcement proceeding, the user seeking to establish the occurrence of an upset shall have the burden of proof.
- (e) Users shall have the opportunity for a judicial determination on any claim of upset only in an enforcement action brought for noncompliance with categorical pretreatment standards.
- (f) Users shall control production of all discharges to the extent necessary to maintain compliance with categorical pretreatment standards upon reduction, loss, or failure of its treatment facility until the facility is restored or an alternative method of treatment is provided. This requirement applies in the situation where, among other things, the primary source of power of the treatment facility is reduced, lost, or fails.

(Ord. No. 4110, § 2(13.1), 6-8-09)

- CODE OF ORDINANCES
Chapter 14 - WATER AND SEWERS
ARTICLE III. - SEWERS
DIVISION 5. - PRETREATMENT

Subdivision XIII. Affirmative Defenses to Discharge Violations

Sec. 14-361. Prohibited discharge standards.

A user shall have an affirmative defense to an enforcement action brought against it for noncompliance with the general prohibitions in subsection [14-155\(a\)](#) or the specific prohibitions in subsections [14-155\(b\)\(1\)](#) through (17) if it can prove that it did not know, or have reason to know, that its discharge, alone or in conjunction with discharges from other sources, would cause pass through or interference and that either:

- (a) A local limit exists for each pollutant discharged and the user was in compliance with each limit directly prior to, and during, the pass through or interference; or
- (b) No local limit exists, but the discharge did not change substantially in nature or constituents from the user's prior discharge when the city was regularly in compliance with its NPDES permit, and in the case of interference, was in compliance with applicable sludge use or disposal requirements.

(Ord. No. 4110, § 2(13.2), 6-8-09)

Sec. 14-362. Bypass.

(a) *[Definitions.]* For the purposes of this section:

- (1) *Bypass* means the intentional diversion of wastestreams from any portion of a user's treatment facility.
- (2) *Severe property damage* means substantial physical damage to property, damage to the treatment facilities which causes them to become inoperable, or substantial and permanent loss of natural resources which can reasonably be expected to occur in the absence of a bypass. Severe property damage does not mean economic loss caused by delays in production.

(b) *[Exceptions.]* A user may allow any bypass to occur which does not cause pretreatment standards or requirements to be violated, but only if it also is for essential maintenance to assure efficient operation. These bypasses are not subject to the provision of subsections (c) and (d).

(c) *Bypass notifications.*

- (1) If a user knows in advance of the need for a bypass, it shall submit prior notice to the city manager, at least ten (10) days before the date of the bypass, if possible.
- (2) A user shall submit oral notice to the city manager of an unanticipated bypass that exceeds applicable pretreatment standards within twenty-four (24) hours from the time it becomes aware of the bypass. A written submission shall also be provided within five (5) days of the time the user becomes aware of the bypass. The written submission shall contain a description of the bypass and its cause; the duration of the bypass, including exact dates and times, and, if the bypass has not been corrected, the anticipated time it is expected to continue; and steps taken or planned to reduce, eliminate, and prevent reoccurrence of the bypass. The city manager may waive the written report on a case-by-case basis if the oral report has been received within twenty-four (24) hours.

(d) *Bypass.*

- (1) Bypass is prohibited, and the city manager may take an enforcement action against a user for a bypass, unless:

- CODE OF ORDINANCES
Chapter 14 - WATER AND SEWERS
ARTICLE III. - SEWERS
DIVISION 5. - PRETREATMENT

Subdivision XIII. Affirmative Defenses to Discharge Violations

- a. Bypass was unavoidable to prevent loss of life, personal injury, or severe property damage;
 - b. There were no feasible alternatives to the bypass, such as the use of auxiliary treatment facilities, retention of untreated wastes, or maintenance during normal periods of equipment downtime. This condition is not satisfied if adequate backup equipment should have been installed in the exercise of reasonable engineering judgment to prevent a bypass which occurred during normal periods of equipment downtime or preventive maintenance; and
 - c. The user submitted notices as required under subsection (c).
- (2) The city manager may approve an anticipated bypass, after considering its adverse effects, if the city manager determines that it will meet the three (3) conditions listed in subsection (d)(1).

(Ord. No. 4110, § 2(13.3), 6-8-09)

Secs. 14-363—14-374. Reserved.

- CODE OF ORDINANCES
Chapter 14 - WATER AND SEWERS
ARTICLE III. - SEWERS
DIVISION 5. - PRETREATMENT

Subdivision XIV. Wastewater Treatment Rates (Reserved)

Subdivision XIV. Wastewater Treatment Rates
(Reserved)

[Secs. 14-375—14-384. Reserved.](#)

Secs. 14-375—14-384. Reserved.

- CODE OF ORDINANCES
Chapter 14 - WATER AND SEWERS
ARTICLE III. - SEWERS
DIVISION 5. - PRETREATMENT

Subdivision XV. Miscellaneous Provisions

Subdivision XV. Miscellaneous Provisions

[Sec. 14-385. Pretreatment charges and fees.](#)

Sec. 14-385. Pretreatment charges and fees.

The city may adopt reasonable fees for reimbursement of costs of setting up and operating the city's pretreatment program, which may include:

- (a) Fees for wastewater discharge permit applications including the cost of processing such applications;
- (b) Fees for monitoring, inspection, and surveillance procedures including the cost of collection and analyzing a user's discharge, and reviewing monitoring reports and certification statements submitted by users;
- (c) Fees for reviewing and responding to accidental discharge procedures and construction;
- (d) Fees for filing appeals;
- (e) Fees to recover administrative and legal costs (not included in subsection (b)) associated with the enforcement activity taken by the city manager to address IU noncompliance; and
- (f) Other fees as the city may deem necessary to carry out the requirements contained herein. These fees relate solely to the matters covered by this ordinance and are separate from all other fees, fines, and penalties chargeable by the city.

(Ord. No. 4110, § 2(15.1),, 6-8-09)